

Having trouble viewing this email? [View it as a Web page.](#)

TDI | State Fire Marshal's Office

Fire alarm sensor recall

Honeywell has recalled the “-IV” Intelligent photoelectric smoke sensors sold with fire alarm systems. The sensor can malfunction and cause the fire alarm system to fail to alert occupants in commercial buildings of a fire.

More information is available on the Consumer Product Safety Commission's [website](#).